



Consumer to provide all materials on the service pole, including the service pole.  
 CVEC to provide the meter base (200 Amp only) and meter.  
 Meter base can be mounted on either side of the service pole.  
 The service pole must be set within 10' of CVEC pole.

**10 FT. PERMANENT OVERHEAD SERVICE  
 FROM CVEC POLE TO SVC POLE**



**CENTRAL VIRGINIA  
 ELECTRIC COOPERATIVE**

**11/07/2012**